

The manufacturer may use the marks:



Certification Report:

JCI 2110089 R003 V1R1

Application Restrictions:

The unit shall be operated in a network and operational environment meeting the assumptions in the product certification report.

Validity:

Product certificate remains valid under conditions:

- The following SDLA certificate remains valid: JCI 1909037 SDLA 2.0.0 Assessment Report
- YMC² ModA Centrifugal Chiller OptiView™ Control Panel V10x remains under security management practices thereby certified

Revision 1.1 August 23, 2022



ISASecure Chartered Laboratory:

exida
80 North Main St.
Sellersville, PA 18960
License: ISCI-CL0001
AClass Cert No: AT-1531



T-171 V1R1

Certificate / Certificat Zertifikat / 合格証

JCI 2110089 C002

exida hereby confirms that the

YMC² ModA Centrifugal Chillers
Johnson Controls International PLC
Cork, Ireland

Conforms to 62443 requirements listed and to requirements shown:

ANSI/ISA-62443-4-1:2018, IEC 62443-4-1:2018 Secure product development lifecycle requirements

ANSI/ISA-62443-4-2:2018, IEC 62443-4-2:2018 Technical security requirements for IACS components

Meeting Requirements for:

ISASecure Component Security Assurance (CSA) 1.0.0 Capability Security Level 1 requirements for embedded devices, referencing errata CSA-102 v1.9

The normative documents and issue dates that define this certification are listed at www.isasecure.org

Assessment	Subject under Assessment	Date	Current release at time of assessment
ISASecure® CSA evaluation	YMC ² ModA Centrifugal Chiller OptiView™ Control Panel	July 27, 2022	V10



Bill Thonson, *[Signature]*

Evaluating Assessor

David A. Johnson

Certifying Assessor