

# Certificate



968/CSA 1003.00/23



<b>Product tested</b>	Programming- and configuration tool for safety related programmable electronic systems	<b>Certificate holder</b>	Schneider Electric Systems USA, Inc. 26521 Rancho Parkway South Lake Forest, CA 92630 USA
<b>Type designation</b>	Triconex TriStation 1131 Details the actual "Revision List"		
<b>Codes and standards</b>	IEC 62443-4-1:2018 (Edition 1.0) IEC 62443-4-2:2019 (Edition 1.0)	ISASecure® Component Security Assurance 1.0.0:2019 ISASecure® CSA 102:2023 Version 2.5	
<b>Scope and result</b>	The Triconex TriStation 1131 complies with the component requirements of the security standards IEC 62443-4-2 Security Level Capability 1 (SL-C 1) and ISASecure® CSA 1.0.0 according to Capability Security Level 1.  The Triconex TriStation 1131 programming- and configuration tool can be used to for developing and testing control/safety applications for Triconex CX V12.x Systems.		
<b>Specific requirements</b>	For the use of the product the safety and security considerations as documented in the product and user guides and the actual Revision List must be considered. This certificate remains valid under the condition that the Triconex TriStation 1131 remains under the security management practices certified by ISASecure® Security Development Lifecycle Assurance certificate SDLA 107 issued to Schneider Electric Systems USA, Inc.		

The issue of this certificate is based upon an examination, whose results are documented in Report No. 968/FSP 2649.00/23 dated 2023-11-20.  
This certificate is valid only for products which are identical with the product tested.

**TÜV Rheinland Industrie Service GmbH**  
Bereich Automation  
Funktionale Sicherheit  
Am Grauen Stein, 51105 Köln

Köln, 2023-11-21

Certification Body Safety & Security for Automation & Grid

Dipl.-Ing. (FH) Sergei Biberdorf