

The manufacturer
may use the marks:



Certification Report:

HON 2205254 R004 V1R0

Application Restrictions:

The unit shall be operated in a network and operational environment meeting the assumptions in the product certification report.

Validity:

Product certificate remains valid under the following conditions:

- The following SDLA certificates remain valid: ISASecure® SDLA certificate numbers HON 2103121 C001 issued to Honeywell Building Technologies and HON 2305073 C001 issued to Tridium, Inc.
- Honeywell Advanced Plant Controller Version 4.10.x.x remains under security management practices thereby certified

Revision 1.1 January 9, 2024



ISASecure Chartered Laboratory:

exida

80 North Main St.
Sellersville, PA 18960
License: ISCI-CL0001

ACLASS Cert No: AT-1531



T-171 V1R6

Certificate / Certificat Zertifikat / 合格証

HON 2205254 C001

exida hereby confirms that the

Honeywell Advanced Plant Controller Honeywell Building Technologies Atlanta, GA

Conforms to 62443 requirements listed and to requirements shown.

ANSI/ISA-62443-4-1:2018, IEC 62443-4-1:2018 Secure product development lifecycle requirements

ANSI/ISA-62443-4-2:2018, IEC 62443-4-2:2019 Technical security requirements for IACS components

Meeting Requirements for:

ISASecure Component Security Assurance (CSA) 1.0.0 Capability Security Level 2 requirements for embedded devices, referencing errata CSA-102 v2.2

The normative documents and issue dates that define this certification are listed at www.isasecure.org

Assessment	Subject under Assessment	Date	Current releases at time of assessment
ISASecure® CSA evaluation	Advanced Plant Controller	Dec. 29, 2023	4.10



Michael Medoff
Evaluating Assessor

David A. Johnson
Certifying Assessor